

Centrale wentylacyjne

Nr centrali	nawiew		wywiew		spr.odzysku rzeczywista	moc nagrzewnicy	moc całkowita chłodnicy	tn zima	tn lato
	nawiew	spręż	wywiew	spręż					
-	m3/h	Pa	m3/h	Pa	%	kW	kW	°C	°C
NW-1	1 775,00	200	1 680,00	200	85,0	6,9	nd	22,0	nd
NW-2	3 855,00	500	3 840,00	500	84,0	13,0	22,1	20,0	16,0
NW-3	1 565,00	300	1 105,00	300	79,0	7,6	nd	22,0	nd
NW-4	11 920,00	300	11 920,00	300	85,0	50,0	55,9	22,0	18,0
NW-4.1	2 385,00	450	2 505,00	450	79,0	8,4	10,4	22,0	18,0
NW-5	8 870,00	300	8 870,00	300	85,0	36,6	41,1	22,0	18,0
NW-WC1	3 020,00	300	3 020,00	300	75,0	11,2	nd	22,0	nd