

Ujęcie i Stacja uzdatniania wody WYDRZANY' 2022

Data	mg Pt/l		µg/l		µg/l		mg/l		pH		mg/l		mg/l		mg/l		mg/l		mg/l		NTU		mg/l		mg/l		µS/cm		mg/l		Wydajność m <sup>3</sup> / h		
	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd	sur	uzd		sur	uzd
22-01-10	19	7	2010	44	399	20	1,56	0,13	7,42	7,08	6,3	2,9	246	233	206	158	59	56	40	73	6,2	0,16	<0,04	<0,04	<0,3	3,70	z3G	akcept.	627	612			82
22-01-11		6		40		<10		0,20		7,14		2,9										0,31					akcept.		599			94	
22-01-17		8		81		17				7,09												0,23					akcept.		626			89	
22-01-25	26	9	2990	45	687	19	2,26	0,10	7,32	7,06	8,5	4,2									4,6	0,13				z3G	akcept.	625	618			89	
22-02-01	18	6	2030	41	465	<10	1,60	0,17	7,37	7,04	6,2	2,9	248	221	210	143	54	51	32	72	3,8	0,14	0,042	0,046	<0,3	3,86	z2G	akcept.	599	585			79
22-02-08		7		91		16		0,20		7,07		3,2										0,21					akcept.		641				
22-02-14		9		161		20		0,20		7,09		4,2										0,38					akcept.		651				
22-02-21	44	7	2580	33	553	<10	2,00	0,16	7,36	7,08	7,5	3,2									1,1	0,13				z3G	akcept.	600	586			85	
22-03-01	21	7	2420	36	482	11	1,78	0,18	7,37	7,08	6,8	3,4	248	239	206	157	48	48	32	68	2,8	0,12	<0,04	0,047	0,56	4,45	z3G	akcept.	582	596			80
22-03-08		7		46		24		0,17		7,04		3,3										0,16					akcept.		608				
22-03-14		7		58		14				6,92												0,13					akcept.		784			114	
22-03-21	32	8	3030	36	741	17	2,24	0,24	7,31	7,01	9,2	4,1									2,5	0,13				z3G	akcept.	658	659			91	
22-04-05	30	7	2370	51	555	13	1,94	0,19	7,36	7,07	7,3	3,2									1,80	0,17				z3G	akcept.	652	651			92	
22-04-11		6		29		12				7,01												0,09							654			135	
22-04-21		8		100		19				6,96												0,24					akcept.		724			276	
22-04-25	33	8	1960	59	444	17	1,44	0,12	7,46	7,04	7,1	4,2	252	274	185	142	66	91	40	80	2,8	0,12	0,044	<0,04	<0,3	4,13	z2G	akcept.	632	752			197
22-05-02		7		39		13				6,92												0,26					akcept.		730			101,5	
22-05-10	27	6	2500	41	608	11	1,68	0,14	7,40	6,96	8,6	3,4									4,3	0,20					akcept.	740	682				
22-05-24	21	7	2130	47	485	18	1,72	0,15	7,41	6,91	6,4	3,3	289	296	199	139	59	117	30	79	3,7	0,12	<0,04	<0,04	<0,3	4,11	z2G	akcept.	614	835			144
22-06-01		8		44		15				7,04												0,14					akcept.		814			151,2	
22-06-07	28	8	2710	54	589	14	2,52	0,29	7,37	6,96	9,6	3,3									8,3	0,16				z1G	akcept.	1046	873			201,3	
22-06-13		9		49		14		0,15		7,10		3,6										0,19					akcept.		901			160	
22-06-20	22	6	1950	48	561	14	1,64	0,17	7,48	6,96	8,4	3,5	272	263	182	126	109	108	49	86	2,9	0,20	<0,04	<0,04	<0,3	3,55	z2G	akcept.	791	804			125
22-06-27		10		49		21				6,98												0,21					akcept.						
22-07-05	26	12	2380	24	609	<10	2,32	0,24	7,51	7,02	7,1	3,2									4,8	0,13					akcept.	812	761			200	
22-07-11		10		42		17				7,00												0,19					akcept.						
22-07-18	25	11	2420	47	652	19	1,92	0,26	7,35	6,99	8,6	3,9	313	320	195	145	267	274	42	78	4,9	0,15	0,047	<0,04	<0,3	4,55	z2G	akcept.	897	921			193
22-07-22																											akcept.						192
22-07-26		7		47		17				7,07												0,29					akcept.						
22-08-02	23	6	1940	69	505	33	1,72	0,11	7,47	6,99	8,1	3,4									3,6	0,24					akcept.	761	765			186	
22-08-10		8		55		22				6,97												0,26					akcept.						
22-08-17		9		231		51				7,00												0,63										190	
22-08-18				120		31																										183	
22-08-22	29	9	2000	186	564	43	1,86	0,33	7,50	6,95	8,0	4,2	275	277	204	157	98	104	42	85	3,9	0,45	0,06	<0,04	<0,3	4,26	z3G	akcept.	768	815			187
22-08-29		9		85		26				6,92												0,27											
22-09-06	27	10	2480	99	778	29	2,16	0,28	7,39	7,06	10,4	4,9									6,8	0,55				z2G	akcept.	900	881			199	
22-09-14		10		78		24				6,96												0,33					akcept.					189	
22-09-19	33	10	2390	109	658	35	2,08	0,24	7,42	7,00	8,7	4,1	304	282	204	151	138	128	47	81	4,4	0,30	<0,04	<0,04	<0,3	4,25	z3G	akcept.	890	885			
22-09-28		9		55		24				6,91												0,33					akcept.		876			214	
22-10-05		10		98		32				6,99												0,32											
22-10-11	21	7	2150	312	568	58	2,40	0,29	7,40	7,11	8,5	3,9									4,8	0,75				z2G	akcept.	661	745			141	
22-10-11				240		59																											
22-10-12				152		32																											
22-10-13				203		45																											
22-10-14				148		29																											
22-10-18				362		123																											110
22-10-18				328		70																											
22-10-19		8		94		31				7,06												0,41											107
22-10-20				66		17																											126
22-10-21				25		16																											114
22-10-24				30		21																											110
22-10-25				29		18																											
22-11-03		12		58		24				7,10																							
22-11-10		8		55		23				6,99																							
22-11-15	19	7	2440	73	550	32	0,93	<0,06	7,40	7,09	7,4	3,3									5,3	0,39				z2G	akcept.	588	602			98	
22-11-21	21	11	2490	127	621	46	1,92	0,15	7,32	7,08	6,7	3,5	250	237	208	164	62	56	23	58	3,9	0,30	<0,04	<0,04	0,51	3,96	z3G	akcept.	754	632			98
22-11-30		13		129		30				7,18																							

min	18	6	1940	24	399	<10	0,93	0,10	7,31	6,91	6,2	2,9	246	221	182	126	48	48	23	58	1,10	0,09	<0,04	<0,04	<0,3	3,55
max	44	13	3030	362	778	123	2,52	0,33	7,51	7,18	10,4	4,9	313	320	210	164	267	274	49	86	8,30	0,75	0,057	<0,04	0,56	4,55
średnia	26	8	2351	91	575	27	1,89	0,19	7,40	7,02																